

$$\text{Leak rate} = \frac{\begin{array}{l} \text{pounds of refrigerant added over past 365 days} \\ \text{(or since leaks were last repaired,} \\ \text{if that period is less than one year)} \end{array}}{\text{pounds of refrigerant in full charge}} \times 100\%$$

(% per year)